

Location ASEAN Sekretariat, Jl. Sisingamangaraja 70 A, Jakarta					
No.	Description	Volume	Unit	Unit Price (IDR)	Total (IDR)
1	Preparation work				
1.1	Mobilization and demobilization material	1	ls		-
1.2	Support Tools	1	ls		-
1.3	Cleaning work area	1	ls		-
2	Replace Cable on Main Panel at Groundfloor				
2.1	Replace Cable on existing panel at ground floor. The work is to replace panel and componen of main panel, the installation of R S T component should follow the standard of electrical safety. The type of cable is NYY Supreme	1	set		-
3	Replace Cable on Chiller				
3.1	Replace cable from Chiller pump to Cooling Tower Panel to Chiller Water Pump 1. The cable is 2x4x25 mm NYY Supreme	64	m		-
3.2	Replace cable from Chiller pump to Cooling Tower Panel to Chiller Water Pump 2. The cable is 2x4x25 mm NYY Supreme	62	m		-
3.3	Replace cable from Chiller pump to Cooling Tower Panel to Chiller Water Pump 3. The cable type is 2x4x25 mm NYY Supreme	58	m		-
3.4	Replace cable from Chiller pump to Colling Tower Panel to CHWP 1. The cable is 2x4x25 mm NYY Supreme	52	m		-
3.5	Replace cable from Chiller pump to Colling Tower Panel to CHWP 2. The cable is 2x4x25 mm NYY Supreme	54	m		-
3.6	Replace cable from Chiller pump to Colling Tower Panel to CHWP 3. The cable is 2x4x25 mm NYY Supreme	56	m		-
3.7	Replace cable from Chiller pump to Coolong Tower Panel to fan Cooling Tower 1. The cable is 4x4 mm NYY Supreme	48	m		-
3.8	Replace cable from Chiller pump to Coolong Tower Panel to fan Cooling Tower 2. The cable is 4x4 mm NYY Supreme	48	m		-
3.9	Replace cable from Chiller pump to Coolong Tower Panel to fan Cooling Tower 3. The cable is 4x4 mm NYY Supreme	57	m		-
3.10	Replace cable and component (brackers, contactor, etc) which found broken on each panel of chiller, cooling tower panel, Fan cooling tower panel. The component brand is Schneider	9	unit		-
Total					-

Closing date for Quotation Submission: 19 September 2018

Work Period:

1 (one) months after signature acceptance of PO

Terms of payment:

40% - Down Payment

55% - Upon completion and acceptance of work

5% - Retention 3 months period

Validity of Quotation:

30 days of the Quotation Date

Conditions/Ketentuan :

- Please attach this Specifications Form to your quotation with your signature below & company's stamp/ Mohon melampirkan Spec. form ini pada penawaran disertai tanda tangan PIC dan cap perusahaan;**
- Please state the availability of the manpower/period of contract;
Mohon cantumkan ketersediaan tenaga kerja/periode kontrak;
- All services provided must meet the requirements. Shall the above requirements are not met, we will cancel the purchase of the above items/
Semua jasa yang disediakan wajib memenuhi kriteria dan ketentuan. Apabila jasa dikerjakan tidak sesuai, maka kami akan membatalkan Purchase Order yang sudah diterbitkan.
- The price in this quotation shall be valid for 30 (thirty) days commencing on the date of submission of quotation
Harga satuan yang tertera pada penawaran wajib berlaku selama 30 (tiga puluh) hari terhitung sejak tanggal penawaran;
- Please exclude VAT 10%, as ASEAN Sekretariat is NOT subjected to VAT/
Mohon tidak mencantumkan PPN 10% pada harga penawaran karena Sekretariat ASEAN tidak dikenakan PPN;
- Please filled the unit price colom of each item works in IDR
Mohon diisi harga satuan pada setiap item pekerjaan dalam Rupiah

.....
Contact Person:
Company:
Date: